Technical Information Manual

Revision n. 10
20 July 2010

MOD. V1495

GENERAL PURPOSE VME BOARD

NPO:
00117/04:V1495.MUTx/10

CAEN will repair or replace any product within the guarantee period if the Guarantor declares that the product is defective due to workmanship or materials and has not been caused by mishandling, negligence on behalf of the User, accident or any abnormal conditions or operations.

CAEN declines all responsibility for damages or injuries caused by an improper use of the Modules due to negligence on behalf of the User. It is strongly recommended to read thoroughly the CAEN User's Manual before any kind of operation.

CE

CAEN reserves the right to change partially or entirely the contents of this Manual at any time and without giving any notice.

Disposal of the Product

The product must never be dumped in the Municipal Waste. Please check your local regulations for disposal of electronics products.

MADE IN ITALY : We stress the fact that all the boards are made in Italy because in this globalized world, where getting the lowest possible price for products sometimes translates into poor pay and working conditions for the people who make them, at least you know that who made your board was reasonably paid and worked in a safe environment. (this obviously applies only to the boards marked "MADE IN ITALY", we can not attest to the manufacturing process of "third party" boards).

TABLE OF CONTENTS

1. GENERAL DESCRIPTION 6

1.1. OVERVIEW 6
1.2. BLOCK DIAGRAM 7

2. TECHNICAL SPECIFICATIONS 8

2.1. PACKAGING 8
2.2. POWER REQUIREMENTS 8
2.3. FRONT PANEL DISPLAYS 8
2.4. FRONT PANEL 9
2.5. MOTHERBOARD SPECIFICATIONS 10
2.6. MEZZANINE SPECIFICATIONS 10
2.7. MEZZANINE BOARDS INSTALLATION 11
2.8. FRONT PANEL CONNECTOR CABLING 11

3. OPERATING MODES 13

3.1. TIMERS 13
3.1.1. Timer0, Timer1 13
3.1.2. Timer2, Timer3 14
3.2. FPGA PROGRAMMING 15
3.2.1. FPGA VME 15
3.2.2. FPGA USER 16

4. VME INTERFACE 17

4.1. REGISTER ADDRESS MAP 17
4.1.1. Configuration ROM 18
4.2. GEO ADDRESS REGISTER 18
4.3. MODULE RESET REGISTER 19
4.4. FIRMWARE REVISION REGISTER 19
4.5. SCRATCH16 REGISTER 19
4.6. SCRATCH32 REGISTER 19
4.7. SELECT VME FPGA FLASH REGISTER 19
4.8. SELECT USER FPGA FLASH REGISTER 19
4.9. VME FPGA FLASH MEMORY 20
4.10. USER FPGA FLASH MEMORY 20
4.11. USER FPGA CONFIGURATION REGISTER 20

5. USER FPGA DEMOS AND PROGRAMMING 21

5.1. INTRODUCTION 21
5.1.1. Advanced Demo applications *22*
5.2. REFERENCE DESIGN KIT 22
5.2.1. V1495HAL *22*
5.2.2. COIN_REFERENCE Design *23*
5.3. INTERFACE DESCRIPTION 24
5.3.1. Global Signals *24*
5.3.2. REGISTER INTERFACE *24*
5.3.3. V1495 Front Panel Ports (PORT A,B,C,G) INTERFACE *25*
5.3.4. V1495 Mezzanine Expansion Ports (PORT D,E,F) INTERFACE *25*
5.3.5. PDL Configuration Interface *26*
5.3.6. Delay Lines and Oscillators I/O *26*
5.3.7. SPARE Interface *26*
5.3.8. LED Interface *26*
5.4. REFERENCE DESIGN DESCRIPTION 27
5.4.1. Mezzanine board interfacing *30*
5.5. REGISTER DETAILED DESCRIPTION 31
5.5.1. V1495 Front Panel Ports Registers (PORT A,B,C,G) *31*
5.5.2. V1495 Mezzanine Expansion Ports Registers (PORT D,E,F) *31*
5.5.3. Delay Selection *31*
5.5.4. PDL DELAY VALUE SETTING AND READBACK *32*
5.5.5. Delay Unit using PDLs *33*
5.5.6. Delay Unit using DLOs *34*
5.6. QUARTUS II WEB EDITION PROJECT 37
5.7. FIRMWARE UPGRADE 40

LIST OF FIGURES

FIG. 1.1: MOD. V1495 BLOCK DIAGRAM 7
FIG. 2.1: MODEL V1495 FRONT PANEL (WITH A395A/B/C PIGGY BACK BOARDS) 9
FIG. 2.2: MULTIPIN CONNECTOR PIN ASSIGNMENT 11
FIG. 2.3: MOD. A967 CABLE ADAPTER 12
FIG. 3.1: TIMERS DIAGRAM 14
FIG. 3.2: GATE PULSE EXAMPLE 14
FIG. 3.3: TIMER2 AND TIMER3 USED TOGETHER FOR HANDLING A GATE PULSE 15
FIG. 3.4: FPGA VME DIAGRAM 15
FIG. 3.5: FPGA USER DIAGRAM 16
FIG. 5.1: USER FPGA BLOCK DIAGRAM 21
FIG. 5.2: FRONT PANEL PORTS INTERFACE DIAGRAM 28
FIG. 5.3: PDL_CONTROL BIT FIELDS 32
FIG. 5.4: DELAY UNIT WITH PDLS 33
FIG. 5.5: PDLS DELAY LINE TIMING 34
FIG. 5.6: DELAY UNIT WITH DLOS 35

FIG. 5.7: DLOS DELAY LINE TIMING 36
FIG. 5.8: QUARTUS II PROJECT BROWSER 38
FIG. 5.9: QUARTUS II NETLIST 38
FIG. 5.10: QUARTUS II HIERARCHICAL STRUCTURE 39
FIG. 5.11: QUARTUS II COMPILER LAUNCHING 39
FIG. 5.12: QUARTUS II COMPILING SUMMARY 40

LIST OF TABLES

TABLE 1.1: AVAILABLE ITEMS 6
TABLE 2.1: MODEL V1495 AND MEZZANINE BOARDS POWER REQUIREMENTS 8
TABLE 2.2: V1495 MOTHERBOARD I/O SECTIONS 10
TABLE 2.3: V1495 MEZZANINE BOARDS 10
TABLE 4.1: ADDRESS MAP FOR THE MODEL V1495 17
TABLE 4.2: ROM ADDRESS MAP FOR THE MODEL V1495 18
TABLE 5.1: COIN_REFERENCE SIGNALS 23
TABLE 5.2: V1495 MEZZANINE EXPANSION PORTS SIGNALS 25
TABLE 5.3: PDL CONFIGURATION INTERFACE SIGNALS 26
TABLE 5.4: DELAY LINES AND OSCILLATORS SIGNALS 26
TABLE 5.5: SPARE INTERFACE SIGNALS 26
TABLE 5.6: LED INTERFACE SIGNALS 27
TABLE 5.7: COIN_REFERENCE REGISTER MAP 28
TABLE 5.8: SELECTION OF THE DELAY LINE 32

1. General description

1.1. Overview

The Mod. V1495 is a VME 6U board, 1U wide, suitable for various digital Gate/Trigger/Translate/Buffer/Test applications, which can be directly customised by the User, and whose management is handled by two FPGA's:
FPGA "Bridge", which is used for the VME interface and for the connection between the VME interface and the 2nd FPGA (FPGA "User") through a proprietary local bus. FPGA "Bridge" manages also the programming via VME of the FPGA "User".
FPGA "User", which manages the front panel I/O channels. FPGA "User" is provided with a basic firmware which allows to perform coincidence matrix, I/O register and asynchronous timers functions.
FPGA "User" can be also free reprogrammed by the user with own custom logic function (see § 5.1). It is connected as slave to the FPGA "Bridge" via CAEN Local Bus, whose protocol shall be used in order to communicate with the FPGA "Bridge" and thus with the VME bus.
The I/O channel digital interface is composed by four sections (A, B, C, G) placed on the motherboard (see § 1.2). The channel interface can be expanded in the D, E, F sections by using up to 3 mezzanine boards (see § 2.6 and § 2.7), which can be added, choosing between the five types developed in order to cover the I/O functions and the ECL, PECL, LVDS, NIM, TTL signals and 16bit DAC (see § 1.2). The maximum number of channels can be expanded up to 194.
The FPGA "User" can be programmed "on the fly" directly via VME, without external hardware tools, without disconnecting the board from the set up, without resetting it or turning the crate off, allowing quick debug operations by the developer with his own firmware. A flash memory on the board can store the different programming file, which can be loaded to the FPGA "User" at any moment.
Four independent digital programmable asynchronous timers are available for Gate/Trigger applications. It is possible to chain them for generating complex Gate/Trigger pulse.

Table 1.1: Available items

Code	Description
WV1495XAAAAA	V1495 - General Purpose VME Board
WA395XAAAAAA	A395A - 32 LVDS/ECL/PECL input channels
WA395XBAAAAA	A395B - 32 LVDS output channels
WA395XCAAAAA	A395C - 32 ECL output channels
WA395XDAAAAA	A395D - 8 NIM/TTL input/output channels
WA395XEAAAAA	A395E - 8 channel 16Bit ±5V DAC
WPERS0149501	V1495 - Customization - 3 A395C Mounting Option
WA967XAAAAAA	A967 - 32 Channel Cable Adapter (1x32 to 2x16)
WFW1495SCXAA	FW1495SC - 128 Channels Latching Scaler for V1495

1.2. Block Diagram



Fig. 1.1: Mod. V1495 Block Diagram

2. Technical specifications

2.1. Packaging

The module is housed in a 6U-high, 1U-wide VME unit. The board is provided the VME P1, and P2 connectors and fits into both VME standard and V430 backplanes.

2.2. Power requirements

The power requirements of the modules are as follows:

Table 2.1: Model V1495 and mezzanine boards power requirements

Power supply	V1495	A395A	A395B	A395C	A395D	A395E
+5 V	1 A	0.1 A	0.1 A	1.4 A	1.1 A	0.3 A

2.3. Front panel displays

The front panel (refer to § 2.4) hosts the following LEDs:

DTACK: *Color:* green.
Function: it lights up green whenever a VME read/write access to the board is performed.

USER: *Color:* green / orange / red.
Function: programmable.

2.4. Front Panel



Fig. 2.1: Model V1495 front panel (with A395A/B/C piggy back boards)

2.5. Motherboard Specifications

The Mod. V1495 Motherboard is composed by four I/O sections (see § 1.2), described in the following table:

Table 2.2: V1495 Motherboard I/O sections

Board	No. of Ch.	Direction	Logic	Signal	Bandwidth	Front panel connector
A/B	32	Input	Direct	LVDS/ECL/PECL (single ended TTL optional) 110ohm Rt. Extended Common Mode input range –4V to +5V; Fail Safe input feature.	200MHz	Robinson Nugent P50E-068-P1-SR1-TG type, (34+34) pins
C	32	Output	Direct	LVDS 100ohm Rl	250MHz	Robinson Nugent P50E-068-P1-SR1-TG type, (34+34) pins
G	2	I/O selectable	TTL IN=Direct TTL OUT=Direct NIM IN=Invert NIM OUT=Direct	NIM/TTL selectable Open/50ohm Rt selectable	250MHz	LEMO 00

2.6. Mezzanine Specifications

The five I/O Mezzanine boards developed so far are described in the following table:

Table 2.3: V1495 Mezzanine boards

Board	No. of Ch.	Direction	Logic	Signal	Bandwidth	Front panel connector
A395A	32	Input	Direct	LVDS/ECL/ PECL (single ended TTL optional) 110ohm Rt. Extended Common Mode input range –4V to +5V; Fail Safe input feature.	200MHz	Robinson Nugent P50E-068-P1-SR1-TG type, (34+34) pins
A395B	32	Output	Direct	LVDS 100ohm Rl	250MHz	Robinson Nugent P50E-068-P1-SR1-TG type, (34+34) pins
A395C	32	Output	Direct	ECL	300MHz	Robinson Nugent P50E-068-P1-SR1-TG type, (34+34) pins
A395D	8	I/O selectable	TTL IN=Direct TTL OUT=Direct NIM IN=Invert NIM OUT=Direct	NIM/TTL selectable Open/50ohm Rt selectable	250MHz	LEMO 00
A395E	8	Output	Analog	16bit resolution ±5V @10kΩ RL ±4V @200Ω RL	N.A.	LEMO 00

2.7. Mezzanine boards installation

In order to install one A395x-series mezzanine board on the V1495 motherboard it is necessary to follow these steps:

- Remove (unscrew) the metal cover (one at will)
- Plug the mezzanine board into the 100 pin connector on the motherboard
- Fix the mezzanine board with the screws

WARNING! A Mounting Option is necessary in order to install three A395C mezzanine boards on the V1495 (see table 1.1)

2.8. Front panel connector cabling

Motherboard I/O sections A, B, C and A395A, A395B and A395C Mezzanine boards feature the Robinson Nugent P50E-068-P1-SR1-TG multipin connector, whose pin set is shown in the following figure:



Fig. 2.2: Multipin connector pin assignment

The CAEN Mod. A967 Cable Adapter allows to adapt each Robinson Nugent Multipin Connector into two 1” 17+17-pin Header-type male connectors (3M, 4634-7301) with locks through two 25 cm long flat cables.

Fig. 2.3: Mod. A967 Cable Adapter

3. Operating modes

3.1. Timers

Gate/Trigger applications require the production of an output signal with programmable width (Gate), whenever an input signal (Trigger) occurs.
Gates can be produced in several ways, according to the system set up, which can be either synchronous or asynchronous.

Synchronous systems:
Input signals are referred to a system clock: they can be sampled by the clock itself and the output is a gate signal (obtained with a counter) whose width (and delay) is a multiple of the clock period. If the application requires a width (and delay) of the Gate signal synchronous but with step resolution higher than the system clock period, this can be achieved by enabling the PLL in the USER FPGA and enter the reference clock on channel G0.

Asynchronous systems:
Input signals are not referred to a system clock. As a consequence the gate signal will be generated without any time reference. It is possible to use the implementation described above, with the freedom of choosing the clock source between external or 40MHz internal. The resulting Gate signal will have stable duration, but with maximum position jitter equal to one clock period.
Such position jitter can be rejected by using the asynchronous timers present on the V1495, which allow to generate references synchronous with the occurred trigger.

3.1.1. Timer0, Timer1

Each timer is based on a programmable delay line. FPGA USER drives a STARTx pulse and, after the programmed delay, it receives the return signal PULSEx. The time difference between transmission and reception (logic implementation inside the FPGA USER) can be used to drive a gate signal. The programming of the delay time can be done manually as binary value either via 8 bit dip switches (SW4 and SW5) or via VME register, with a 1ns step resolution (max step delay = 255ns). The software setting has higher priority with respect to the dip switches.
The following figure shows a diagram of the timers usage:



Tdly= Toffset + Tset
Toffset = 30 ± 2ns
Tset = SETBINARY * 1ns
STARTx-WIDTHMIN = 320ns recommended (22ns absolute min.)
STARTx-PERIODMIN = 640ns recommended (46ns absolute min.)

Fig. 3.1: Timers diagram

The use of STARTx signals with timing shorter than those recommended is possible, although the linearity on the set delay scale is no longer guaranteed.

3.1.2. Timer2, Timer3

Each timer is made up of one digital circuit which produces a typical fixed time base with 10ns period and 50% duty cycle. These timers are proposed for generating any Gate pulse > 10ns with a 10ns step. The following figure shows an example of a Gate generation made with Timer2 and n.3 PULSE width.



Fig. 3.2: Gate pulse example

FPGA USER drives a /STARTx pulse and after T_{EN} time FPGA USER will receive a PULSEx clock signal. A counter with clock = PULSEx implemented in the FPGA USER, allows to generate a pulse with programmable duration. It is possible to reduce to one half (5ns) the counter step by advancing the counter on both sides of PULSEx. Since the circuit is completely digital, no recovery time is necessary between one stop and the following start: it is thus possible to generate multiple gate pulses with very high rate. Timer2 and Timer3 can be used together for handling one single Gate pulse from multiple overlapped triggers.



Fig. 3.3: Timer2 and Timer3 used together for handling a Gate pulse

3.2. FPGA Programming

The programming of FPGA VME and FPGA USER are handled by two independent microcontrollers + flash memory. The updating of the firmware contained in the flash memories does not require the use of external tools and can be executed via VME.
The flash related to FPGA VME contains the firmware dedicated to the interface of the board with the FPGA USER and the VME bus; such firmware is developed by CAEN.
The flash related to the FPGA USER contains the firmware developed by the User according to his own application requirements.

3.2.1. FPGA VME

The microcontroller provides the firmware uploading at board's power on. The flash memory contains two versions of the firmware, which can be selected manually via jumper (Standard or Backup).



Fig. 3.4: FPGA VME diagram

3.2.2. FPGA USER

The microcontroller provides the firmware uploading at board's power on. The flash memory contains one firmware image only (Standard).



Fig. 3.5: FPGA USER diagram

FPGA VME aim is to handle the operation of FPGA USER, which can be programmed on the fly, i.e. without turning off the system, thus allowing quick debug operations by the Developer.
Register implemented on FPGA VME allows the following operations:

- FPGA USER flash memory programming.
- FPGA USER updating.

4. VME Interface

FPGA VME Firmware provides the following features:

- Both 16 and 32 bit data mode accesses to FPGA User memory space (Base + 0x1000÷0x7FFC)
- 32 bit Block transfer (BLT) from FPGA User. VME address space Base + 0x0000-0x0FFC is reserved for BLT from FPGA User; any BLT access to such space translates into a read access to Local Bus address 0x0000. V1495 DEMO2 package (see § 5.6) provides an example of BLT handling in User FPGA.

N.B.: FPGA VME Firmware releases older than 1.0 do not support:

- 32bit single accesses
- BLT accesses

4.1. Register address map

The Address map for the Model V1495 is listed in Table 4.1. All register addresses are referred to the Base Address of the board, i.e. the addresses reported in the Tables are the offsets to be added to the board Base Address.

Table 4.1: Address Map for the Model V1495

ADDRESS	REGISTER/CONTENT	ACCESS MODE		Read/Write
Base + 0x0000-0x0FFC	USER FPGA Block transfer	A24/A32	D16/D32/BLT	R
Base + 0x1000÷0x7FFC	USER FPGA Access[1]	A24/A32	D16/D32	R/W
Base + 0x8000	*reserved*	A24/A32	D16/D32	R/W
Base + 0x8002	*reserved*	A24/A32	D16/D32	R
Base + 0x8004	*reserved*	A24/A32	D16/D32	R/W
Base + 0x8006	*reserved*	A24/A32	D16/D32	R/W
Base + 0x8008	Geo Address_Register	A24/A32	D16/D32	R
Base + 0x800A	Module Reset	A24/A32	D16/D32	W
Base + 0x800C	Firmware revision	A24/A32	D16/D32	R
Base + 0x800E	*Select VME FPGA Flash*	A24/A32	D16/D32	R/W
Base + 0x8010	*VME FPGA Flash memory*	A24/A32	D16/D32	R/W
Base + 0x8012	*Select USER FPGA Flash*	A24/A32	D16/D32	R/W
Base + 0x8014	*USER FPGA Flash memory*	A24/A32	D16/D32	R/W
Base + 0x8016	*USER FPGA Configuration*	A24/A32	D16/D32	R/W
Base + 0x8018	Scratch16	A24/A32	D16/D32	R/W
Base + 0x8020	Scratch32	A24/A32	D32	R/W
Base + 0x8100÷0x81FE	*Configuration ROM*	A24/A32	D16/D32	R

[1] FPGA VME Firmware releases older than Rel. 1.0 allow D16 accesses to Base + 0x0000÷0x7FFC memory space

4.1.1. Configuration ROM

The following registers contain some module's information according to the Table 3.2, they are D16/D32 accessible (read only):

- **OUI**: manufacturer identifier (IEEE OUI)
- **Version**: purchased version
- **Board ID**: Board identifier
- **Revision**: hardware revision identifier
- **Serial MSB**: serial number (MSB)
- **Serial LSB**: serial number (LSB)

Table 4.2: ROM Address Map for the Model V1495

Description	Address	Content
checksum	0x8100	
checksum_length2	0x8104	
checksum_length1	0x8108	
checksum_length0	0x810C	
constant2	0x8110	
constant1	0x8114	
constant0	0x8118	
c_code	0x811C	
r_code	0x8120	
oui2	0x8124	0x00
oui1	0x8128	0x40
oui0	0x812C	0xE6
vers	0x8130	
board2	0x8134	0x00
board1	0x8138	0x05
board0	0x813C	0xD7
revis3	0x8140	
revis2	0x8144	
revis1	0x8148	
revis0	0x814C	
sernum1	0x8180	
sernum0	0x8184	

These data are written into one Flash page; at Power ON the Flash content is loaded into the Configuration ROM.

4.2. GEO Address Register

(Base Address + 0x8008, read, D16/D32)
The register content is the following:

Bit	Function
[15-5]	reserved
[4-0]	GEO ADDRESS 4 - 0

This register allows read back of the level of GEO pins for the selected board. The register content is valid only for the VME64X board version. The register content for the VME64 version is 0x1F.

4.3. Module Reset Register

(Base Address + 0x800A write only, D16/D32)
A dummy access to this register allows to generate a single shot RESET of the module.

4.4. Firmware Revision Register

(Base Address + 0x800C, read only, D16/D32)

Bit	Function
[15-8]	X
[7-0]	Y

This register contains the firmware revision number X.Y coded on 16 bit. For instance, the REV. 1.2 register content is: 0x102

4.5. Scratch16 Register

(Base Address + 0x8018, D16/D32, read/write)
This register allows to perform 16 bit test accesses for test purposes.

4.6. Scratch32 Register

(Base Address + 0x8020, D32, read/write)
This register allows to perform 32 bit test accesses for test purposes.

4.7. Select VME FPGA Flash Register

(Base Address + 0x800E, read/write, D16/D32)
This register allows the VME FPGA configuration update (stored into on-board flash memory) via VMEBUS.
The configuration can be updated by the user by means of the CVUpgrade software (developed and distributed by CAEN), see § 5.7.

4.8. Select USER FPGA Flash Register

(Base Address + 0x8012, read/write, D16/D32)
This register allows USER FPGA configuration update (stored into on-board flash memory) via VMEBUS.
The configuration can be updated by the user by means of the CVUpgrade software (developed and distributed by CAEN), see § 5.7.

4.9. VME FPGA Flash Memory

(Base Address + 0x8010, read/write, D16/D32)
This register allows the VME FPGA configuration update (stored into on-board flash memory) via VMEBUS.
The configuration can be updated by the user by means of the CVUpgrade software (developed and distributed by CAEN), see § 5.7.

4.10. USER FPGA Flash Memory

(Base Address + 0x8014, read/write, D16/D32)
This register allows the USER FPGA configuration update (stored into on-board flash memory) via VMEBUS.
The configuration can be updated by the user by means of the CVUpgrade software (developed and distributed by CAEN), see § 5.7.

4.11. USER FPGA Configuration Register

(Base Address + 0x8016, read/write, D16/D32)

Bit	Function
[15-1]	reserved
[0]	IMAGE_SELECT

This register allows the update of the USER FPGA configuration. A write access to this register generates a configuration reload. The configuration image (Standard) will be uploaded into the USER FPGA as the IMAGE_SELECT bit is set to 1 (default).

5. USER FPGA Demos and Programming

5.1. Introduction

The CAEN V1495 board houses a user-customizable FPGA (called USER FPGA); the board is delivered with a reference design kit, loaded on the USER FPGA; the detailed description is available in sections § 5.2 through § 5.4.1.
This application allows a virtual access to the User FPGA through "Hardware Abstraction Layer", see (§ 5.2.1), and shows examples of

- delay lines use
- A, B, C, G (see § 2.5) ports interface functions
- Read/write capabilities from/to expansion boards (A395A, A395B, A395C, A395D) on E, F, G ports

The COIN_REFERENCE reference design illustrates how to use the USER FPGA to implement a Coincidence Unit & I/O Register Unit. This design can be customized by the user in order to adapt its functionality to his own needs.



Fig. 5.1: USER FPGA block diagram

The Demo project is available at the download section of the webpage

http://www.caen.it/nuclear/product.php?mod=V1495

and its source code can be adapted by updating the *coin_reference.vhd* file.

5.1.1. Advanced Demo applications

Moreover, in order to help the Users to develop advanced software applications for the V1495, CAEN provides several demo applications (four applications are available so far), freely available (both source codes and documentation), at the download section of the webpage

http://www.caen.it/nuclear/product.php?mod=V1495

These applications do not use the HAL (Hardware Abstraction Layer), like the built-in demo, in order to help the hardware interfacing. This is done in order to offer to the end user a further degree of freedom.

The applications implement the following capabilities:

- **Demo 1**
  - *Gate Pattern*
    - AND/OR function between I/Os
    - Single Read/Write access on VME
- **Demo 2**
  - *Pattern Recorder*
    - FIFO/PLL
    - Single Read/Write access on VME
    - Block Transfer Mode (BLT)
- **Demo 3**
  - *DAC*
    - I/O Expansion - A395E (DAC)
    - Single Read/Write access on VME
- **Demo 4**
  - *Gate & Delay Generator*
    - AND/OR function between I/Os
    - I/O Expansion - A395D
    - Single Read/Write access on VME
    - Prog/Free Running Delay Line (PDL/FDL)

5.2. Reference Design Kit

5.2.1. V1495HAL

The V1495 Hardware Abstraction Layer (V1495HAL) is a HDL module provided, in Verilog format at netlist level, in order to help the hardware interfacing.

5.2.2. COIN_REFERENCE Design

The COIN_REFERENCE design VHDL entity is the interface to the V1495HAL. If the User wishes to use V1495HAL to develop his own application on the V1495 platform, the VHDL entity must not be modified: this means that signals names and function of the COIN_REFERENCE entity must be used, as shown in the following table:

Table 5.1: COIN_REFERENCE signals

PORT NAME	DIRECTION	WIDTH	DESCRIPTION
GLOBAL SIGNALS			
NLBRES	IN	1	Async Reset (active low)
LCLK	IN	1	Local Bus Clock (40 MHz)
REGISTER INTERFACE			
REG_WREN	IN	1	Write pulse (active high)
REG_RDEN	IN	1	Read pulse (active high)
REG_ADDR	IN	16	Register address
REG_DIN	IN	16	Data from CAEN Local Bus
REG_DOUT	OUT	16	Data to CAEN Local Bus
USR_ACCESS	IN	1	Current register access is at user address space(Active high)
V1495 Front Panel Ports (PORT A,B,C,G) INTERFACE			
A_DIN	IN	32	In A (32 x LVDS/ECL)
B_DIN	IN	32	In B (32 x LVDS/ECL)
C_DOUT	OUT	32	Out C (32 x LVDS)
G_LEV	OUT	1	Output Level Select (0=>TTL; 1=> NIM)
G_DIR	OUT	1	Output Enable (0=>Output, 1=>Input)
G_DOUT	OUT	2	Out G - LEMO (2 x NIM/TTL)
G_DIN	IN	2	In G – LEMO (2 x NIM/TTL)
V1495 Mezzanine Expansion Ports (PORT D,E,F) INTERFACE			
D_IDCODE	IN	3	D slot mezzanine Identifier
D_LEV	OUT	1	D slot Port Signal Level Select (the level selection depends on the mezzanine expansion board mounted onto this port)
D_DIR	OUT	1	D slot Port Direction
D_DIN[2]	IN	32	D slot Data In Bus
D_DOUT	OUT	32	D slot Data Out Bus
E_IDCODE	IN	3	E slot mezzanine Identifier
E_LEV	OUT	1	E slot Port Signal Level Select (the level selection depends on the mezzanine expansion board mounted onto this port)
E_DIR	OUT	1	E slot Port Direction
E_DIN	IN	32	E slot Data In Bus
E_DOUT	OUT	32	E slot Data Out Bus
F_IDCODE	IN	3	F slot mezzanine Identifier

[2] The I/O channels of the A395D Mezzanine board are mapped on the 8 LSB of D_DIN, D_DOUT, E_DIN, E_DOUT, F_DIN, F_DOUT signals

PORT NAME	DIRECTION	WIDTH	DESCRIPTION
F_LEV	OUT	1	F slot Port Signal Level Select (the level selection depends on the mezzanine expansion board mounted onto this port)
F_DIR	OUT	1	F slot Port Direction
F_DIN	IN	32	F slot Data In Bus
F_DOUT	OUT	32	F slot Data Out Bus
PDL CONFIGURATION INTERFACE			
PDL_WR	OUT	1	Write Enable
PDL_SEL	OUT	1	PDL Selection (0=>PDL0, 1=>PDL1)
PDL_READ	IN	8	Read Data
PDL_WRITE	OUT	8	Write Data
PDL_DIR	OUT	1	Direction (0=>Write, 1=>Read)
DELAY LINES AND OSCILLATORS I/O			
PDL0_OUT	IN	1	Signal from PDL0 Output
PDL1_OUT	IN	1	Signal from PDL1 Output
DLO0_OUT	IN	1	Signal from DLO0 Output
DLO1_OUT	IN	1	Signal from DLO1 Output
PDL0_IN	OUT	1	Signal to PDL0
PDL1_IN	OUT	1	Signal to PDL1 Input
DLO0_GATE	OUT	1	Signal to DLO0 Input
DLO1_GATE	OUT	1	Signal to DLO1 Input
SPARE INTERFACE			
SPARE_OUT	OUT	12	SPARE Data Out
SPARE_IN	IN	12	SPARE Data In
SPARE_DIR	OUT	1	SPARE Direction
LED INTERFACE			
RED_PULSE	OUT	1	RED Led Pulse (active high)
GREEN_PULSE	OUT	1	GREEN Led Pulse (active high)

5.3. Interface description

5.3.1. Global Signals

The nLBRES must be used as an asynchronous reset signal by the user. An active low pulse will be generated when a write is done at the Module Reset register address (see § 4.1).
The LBCLK is a 40 MHz clock. It is the FPGA main clock.

5.3.2. REGISTER INTERFACE

The signals of the Register Interface allows to read/write into the USER FPGA registers, which can be accessed via VMEbus. The COIN_REFERENCE module shows how to implement a set of registers.

The following table shows the registers map as it is provided. Each register address is coded via constants in V1495pkg.vhd file. This file allows to modify the registers map; all registers allow D16/D32 accesses (write only, read only or read/write). Registers default

value is the value after a reset for write only and read/write registers; read only registers return the status of the signals read by the FPGA and have no default value.

The Register Interface allows to abstract the VME registers access. The User can access a simple register interface: two signals (REG_WREN e REG_RDEN) are pulses with a one clock cycle duration which enables respectively a write or a read access to a register. REG_ADDR signal represents the register address.

Writing into a register:
In case of a write operation into a register via VME, the 16 bit datum is available through the REG_DIN signal. The datum is guaranteed stable on the CLK leading edge where REG_WREN is active. The register access is valid only when USR_ACCESS is at logic level = 1.

Reading from a register:
In case of a read operation from a register via VME, the datum to be returned must drive the REG_DOUT and be stable on the CLK leading edge, where REG_RDEN is active. The register access is valid only when USR_ACCESS is at logic level = 1.

5.3.3. V1495 Front Panel Ports (PORT A,B,C,G) INTERFACE

These signals allows to handle the interface with the motherboard ports A, B, C, G. A_DIN and B_DIN signals show the logic level of A and B ports (32 bit, input only).
The output logic level on port C can be set via C_DOUT signal.
The logic level on port G (LEMO connectors) can be set via G_LEV signal; the direction via G_DIR, the datum to be written via G_DOUT or to be read via G_DIN.

5.3.4. V1495 Mezzanine Expansion Ports (PORT D,E,F) INTERFACE

These signals allows to handle the interface with the piggy back board ports D, E, F.
The following table explains the available signals:

Table 5.2: V1495 Mezzanine Expansion Ports signals

Port:	Signal:	Function:	Applies to:
D	D_DIR	Selects direction	Bidirectional port
	D_DIN	Read the logic level	Input/Bidirectional
	D_DOUT	Set the logic level	Output/Bidirectional
	D_ IDCODE	Read IDCODE for piggy back identification	All
	D_LEV	Set the logic level	Output/Bidirectional
E	E_DIR	Selects direction	Bidirectional port
	E_DIN	Read the logic level	Input/Bidirectional
	E_DOUT	Set the logic level	Output/Bidirectional
	E_ IDCODE	Read IDCODE for piggy back identification	All
	E_LEV	Set the logic level	Output/Bidirectional
F	F_DIR	Selects direction	Bidirectional port
	F_DIN	Read the logic level	Input/Bidirectional
	F_DOUT	Set the logic level	Output/Bidirectional
	F_ IDCODE	Read IDCODE for piggy back identification	All
	F_LEV	Set the logic level	Output/Bidirectional

5.3.5. PDL Configuration Interface

PDL Configuration Interface signals are as follows:

Table 5.3: PDL Configuration Interface signals

PDL_WR	OUT	1	Write Enable
PDL_SEL	OUT	1	PDL Selection (0=>PDL0, 1=>PDL1)
PDL_READ	IN	8	Read Data
PDL_WRITE	OUT	8	Write Data
PDL_DIR	OUT	1	Direction (0=>Write, 1=>Read)

5.3.6. Delay Lines and Oscillators I/O

Delay Lines and Oscillators signals are as follows (see also § 5.5.5 and § 5.5.6):

Table 5.4: Delay Lines and Oscillators signals

PDL0_OUT	IN	1	Signal from PDL0 Output
PDL1_OUT	IN	1	Signal from PDL1 Output
DLO0_OUT	IN	1	Signal from DLO0 Output
DLO1_OUT	IN	1	Signal from DLO1 Output
PDL0_IN	OUT	1	Signal to PDL0
PDL1_IN	OUT	1	Signal to PDL1 Input
DLO0_GATE	OUT	1	Signal to DLO0 Input
DLO1_GATE	OUT	1	Signal to DLO1 Input

5.3.7. SPARE Interface

These signals allow to set and read the status of SPARE pin present on the board.

Table 5.5: SPARE Interface signals

SPARE_OUT	OUT	12	SPARE Data Out
SPARE_IN	IN	12	SPARE Data In
SPARE_DIR	OUT	1	SPARE Direction

5.3.8. LED Interface

These signals, when active for one clock cycle, allow to generate a blink of the relevant Led.

Table 5.6: LED Interface signals

RED_PULSE	OUT	1	RED Led Pulse (active high)
GREEN_PULSE	OUT	1	GREEN Led Pulse (active high)

5.4. Reference design description

The reference design preloaded into the USER FPGA is given as a design guide. It is a full functional application of the usage of the board as a concidence and/or I/O register unit. This reference design give access to A,B,C,G ports. So no mezzanine expansion cards are needed in order to use this design.

The MODE register can be used to set the preferred operating mode. When the board is switched on, the default operating mode is I/O Register mode.

In I/O Register Mode, C port is directly driven by the C_CONTROL register. The coincidence is anyway still active so that a pulse in generated on G port when a coincidence event is detected.
In Coincidence Mode, the C port is used to report the coincidence operator on A and B port. In this case the C port can be masked through a mask register (C_MASK).
A gate pulse is generated on G port when data patterns on input ports A and B satisfy a trigger condition.
The trigger condition implemented in this reference design is true when a bit-per-bit logic operation on port A and B
is true. The logic operator applied to Port A and B is selectable by means of a register bit (MODE Register Bit 4).
If MODE bit 4 is set to '0', an AND logic operation is applied to corresponding bits in Port A and B (i.e. A(0) AND B(0), A(1) AND B(1) etc.).
In this case, a trigger is generated if corresponding A and B port bits are '1' at the same time.
If MODE bit 4 is set to '1', an OR logic operation is applied to corresponding bits in Port A and B (i.e. A(0) OR B(0), A(1) OR B(1) etc.).
In this case, a trigger is generated if there is a '1' on one bit of either port A or B.
Port A and B bits can be singularly masked through a register, so that a '1' on that bit doesn't generate any trigger.
Expansion mezzanine cards can be directly controlled through registers already implemented in this design.
The expansion mezzanine is identified by a unique identification code that can be read through a register.



Fig. 5.2: Front Panel Ports Interface Diagram

The following table illustrates the the register map of the USER FPGA reference design (COIN_REFERENCE).

Table 5.7: COIN_REFERENCE register map

NAME	ADDRESS	DATA SIZING	ACCESS	NOTES	DEFAULT
A_STATUS_L	0x1000	D16/D32	RO	Port A status. This register reflects A[15:0] bit status.	
A_STATUS_H	0x1002	D16/D32	RO	Port A status. This register reflects A[31:16] bit status.	
B_STATUS_L	0x1004	D16/D32	RO	Port B status. This register reflects B[15:0] bit status.	
B_STATUS_H	0x1006	D16/D32	RO	Port B status. This register reflects B[31:16] bit status.	
C_STATUS_L	0x1008	D16/D32	RO	Port C status. This register reflects C[15:0] bit status.	
C_STATUS_H	0x100A	D16/D32	RO	Port C status. This register reflects C[31:16] bit status.	
A_MASK_L	0x100C	D16/D32	WO	Port A mask. This register masks A[15:0]. Mask bit is active low.	X"FFFF"
A_MASK_H	0x100E	D16/D32	WO	Port A mask. This register masks A[31:16]. Mask bit is active low.	X"FFFF"
B_MASK_L	0x1010	D16/D32	WO	Port B mask. This register masks B[15:0]. Mask bit is active low.	X"FFFF"
B_MASK_H	0x1012	D16/D32	WO	Port B mask. This register masks B[31:16]. Mask bit is active low.	X"FFFF"
C_MASK_L	0x1014	D16/D32	WO	Port C mask. This register masks	X"FFFF"

NAME	ADDRESS	DATA SIZING	ACCESS	NOTES	DEFAULT
				C[15:0]. Mask bit is active low.	
C_MASK_H	0x1016	D16/D32	WO	Port C mask. This register masks C[31:16]. Mask bit is active low.	X"FFFF"
GATEWIDTH	0x1018	D16/D32	WO	Gate signal width. This number represents a multiple of the selected delay line period (see detailed description)	X"0004"
C_CONTROL_L	0x101A	D16/D32	WO	Port C control. When the port C is configured to be an output under register control (see MODE register), the status of C[15:0] is controlled by this register.	X"0000"
C_CONTROL_H	0x101C	D16/D32	WO	Port C control. When the port C is configured to be an output under register control (see MODE register), the status of C[31:16] is controlled by this register.	X"0000"
MODE	0x101E	D16/D32	WO	It configures the behaviour of the system: MODE[1:0]: DELAY SEL MODE[3]: UNIT_MODE '0': Coincidcence Unit '1': I/O Register MODE[4]:OPERATOR '0': C= A AND B; '1': C = A OR B; MODE[5]:PULSE_MODE See Description	X"0008"; -- Default : I/O Register Mode.
SCRATCH	0x1020	D16/D32	RW	This register is available to test read and write to a register.	X"5A5A"
G CONTROL	0x1022	D16/D32	W	Only Bit 0 (G_CONTROL(0)) is used in this reference design. It can be used to select G output level: '0': TTL '1': NIM	X"0000"
D_CONTROL_L	0x1024	D16/D32	RW	With A395D [bit1=data bus direction]: 0 = OUT; 1 = IN [bit0=mezzanine output level]: 0 = TTL; 1 = NIM [bit15..2]: reserved	X"0000"
D_CONTROL_H	0x1026	D16/D32	RW	reserved	X"0000"
D_DATA_L	0x1028	D16/D32	RW	D port Data [15:0] Read from IN Write to OUT	X"0000"
D_DATA_H	0x102A	D16/D32	RW	D port Data [31:16] Read from IN Write to OUT	X"0000"
E_CONTROL_L	0x102C	D16/D32	RW	With A395D [bit1=data bus direction]: 0 = OUT; 1 = IN [bit0=mezzanine output level]: 0 = TTL; 1 = NIM [bit15..2]: reserved	X"0000"
E_CONTROL_H	0x102E	D16/D32	RW	reserved	X"0000"
E_DATA_L	0x1030	D16/D32	RW	E port Data [15:0] Read from IN Write to OUT	X"0000"
E_DATA_H	0x1032	D16/D32	RW	E port Data [31:16] Read from IN	X"0000"

NAME	ADDRESS	DATA SIZING	ACCESS	NOTES	DEFAULT
				Write to OUT	
F_CONTROL_L	0x1034	D16/D32	RW	With A395D [bit1=data bus direction]: 0 = OUT; 1 = IN [bit0=mezzanine output level]: 0 = TTL; 1 = NIM [bit15..2]: reserved	X"0000"
F_CONTROL_H	0x1036	D16/D32	RW	reserved	X"0000"
F_DATA_L	0x1038	D16/D32	RW	F port Data [15:0] Read from IN Write to OUT	X"0000"
F_DATA_H	0x103A	D16/D32	RW	F port Data [31:16] Read from IN Write to OUT	X"0000"
REVISION	0x103C	D16/D32	RW	Firmware revision . For example, the register content for release 1.0 is X"0100".	X"XXYY"
PDL_CONTROL	0x103E	D16/D32	RW	Bit 0 allows to either set the PDL delay; 0 = delay set via VMEbus (content of PDL_DATA register) 1 = delay set via on-board switches (switch value is content of PDL_DATA register) [bit15..1]: reserved	X"0001"
PDL_DATA	0x1040	D16/D32	RW	Programmable delay line setting	X"0000"
D_IDCODE	0x1042	D16/D32	RO	Read Slot D mezzanine ID Code. ID Code is X"0007" if no mezzanine is plugged.	
E_IDCODE	0x1044	D16/D32	RO	Read Slot E mezzanine ID Code. ID Code is X"0007" if no mezzanine is plugged	
F_IDCODE	0x1046	D16/D32	RO	Read Slot F mezzanine ID Code. ID Code is X"0007" if no mezzanine is plugged	

5.4.1. Mezzanine board interfacing

The Reference Design can be used to interface with A395A-B-C-D mezzanines (interface with A395E is not supported; see § 5.1.1); when one mezzanine board is plugged into either D,E,F port, then it is possible to:

- Select I/O Direction , logical level (NIM/TTL), through x_CONTROL registers (D_CONTROL, E_CONTROL or F_CONTROL, depending on which port the mezzanine card is plugged into)
- Read/Write data from/to mezzanine inputs: read/write register x_DATA_L or x_DATA_H (x = D,E or F, depending on which port the mezzanine card is plugged into).

The mezzanine port directions can be set through x_CONTROL register, therefore if x_CONTROL[1] = 0, all mezzanine card ports are output, all inputs when such bit is set to 1.

Moreover, with A395D mezzanine, the ports can be individually used also as inputs even if the common I/O direction is set to output, since the A395D output stage has a recessive state (logical level 0). Therefore, if x_CONTROL[1] is set to 0 (all ports are outputs), but, for instance, x_DOUT[0] is driven to 0, then it is possible to read port 0 value into corresponding x_DIN[0] bit; in this case, 50Ohm termination on corresponding port (through internal switches) must be enabled.

5.5. REGISTER DETAILED DESCRIPTION

5.5.1. V1495 Front Panel Ports Registers (PORT A,B,C,G)

The Front Panel ports (A,B,C,G) can be configured and accessed using a set of registers:
The x_MASK_y (x can be A,B,C; y can be L or H) registers can be used to selectively mask a bit of a port. Each status register is split into two 16 bit register (MASK_L corresponds to MASK[15:0], while MASK_H corresponds to MASK[31:16]). There is not a MASK register associated with G port. Each bit of the input ports (A,B) mask registers are internally used in a logic AND operation with the corresponding bit of the port, so it is an active low mask bit. For instance, when A_ MASK _L[0] is set to '0', the A[0] bit is internally masked (logic '0').
Each bit of the output port (C) mask register is internally used in a logic AND operation with the corresponding bit of the internal signal, so it is an active low mask bit. For instance, when C_ MASK _L[0] is set to '0', the C[0] bit is masked (output bit is stuck at '0').

The x_STATUS_y (x can be A,B,C; y can be L or H) registers can be used to read back eack port bit. Each status register is split into two 16 bit register (STATUS_L corresponds to STATUS[15:0], while STATUS_H corresponds to STATUS[31:0]). There is not a STATUS register associated with G port. The x_STATUS_y register reflects the status of the unmasked input and output ports.

A control register (C_CONTROL) is available to set the C port when the board is configured in I/O register mode.

5.5.2. V1495 Mezzanine Expansion Ports Registers (PORT D,E,F)

The mezzanine expansion ports (D,E,F) can be configured and accessed using a set of registers:
In this reference design, no mask register is implemented for the expansion ports.

The x_DATA_y (x can be D,E,F; y can be L or H) registers can be used to read back each port bit. Each status register is split into two 16 bit register (D_DATA_L corresponds to D[15:0], while D_DATA_H corresponds to D[31:16]). The expansion ports can be bidirectional. In case the port is configured as an output, the register value set the port value. In case the port is configured as an input, the register content reflects current port value.

A x_CONTROL register (x can be D,E,F) is available to set the corresponding port direction and logic level selection.

5.5.3. Delay Selection

The selection of the asynchronous timer is made through the MODE register by means of the DELAY_SEL bit (MODE[1:0]).
The selection of the delay line is made according to the following table:

Table 5.8: Selection of the delay line

MODE[1]	MODE[0]	DELAY LINE
0	0	PDL0
0	1	PDL1
1	0	DLO0
1	1	DLO1

5.5.4. PDL DELAY VALUE SETTING AND READBACK

The programmable delay lines chip available on board can be programmed with a specific delay using :
on-board 8 bit dip-switch (SW6 for Delay 0 and SW5 for Delay1 on motherboard)
via VMEbus
Two registers are available to configure PDLs:
PDL_CONTROL
PDL_DATA

PDL_CONTROL is used to:
Select target PDL for read/write operations
Enable delay update
Select programming mode (via VME register or by on-board switches)
The PDL_CONTROL bit fields are shown in the following figure:



Fig. 5.3: PDL_CONTROL bit fields

PDL_WR = '1' enables the updating of the PDL delay value: in this way, the delay value set either via dip switch or via PDL_DATA register is automatically loaded. By setting this bit to 0, the delay value cannot be changed.

PDL_DIR allows to select the source of data for PDL programming:
0: the selected PDL has as delay value on its parallel programming bus the dip switch value.
1: the selected PDL has as delay value on its parallel programming bus the PDL_DATA register 8 LSB

PDL_SEL allows to select one of the PDL's (PDL0 and PDL1) for read/write operations.
PDL_DATA register is used to:
Write the delay value for the next delay update via VMEbus
Read the on-board switch status

Examples:
updating of PDL0 delay via switch: the default value in the PDL_CONTROL allows to update the delay directly via dip switch just after the board turning ON; each change in the dip switch status set immediately a new delay value.

The sequence to be followed is:

Step 1: write 0x1 in the PDL_CONTROL register
Step2: update the dip switches value

B) updating of PDL1 delay via switch:

Step 1: write 0x5 in the PDL_CONTROL register
Step 2: update the dip switches value

C) updating of PDL0 delay via VMEbus:

Step 1: write 0x3 in the PDL_CONTROL register
Step2: write the delay value in the PDL_DATA register

D) updating of PDL1 delay via VMEbus:

Step 1: write 0x7 in the PDL_CONTROL register
Step2: write the delay value in the PDL_DATA register

GATE WIDTH (USING Delay Line Oscillators)
The GATEWIDTH register can be used to set the gate signal width on the G port (see Delay Unit using DLOs, see § 5.5.6).

5.5.5. Delay Unit using PDLs

The following diagram shows the implementation of the DELAY_UNIT using the one of the two programmable delay lines (PDL) available on the boards.



Fig. 5.4: Delay Unit with PDLs



Fig. 5.5: PDLs Delay line timing

The pulse width generated using PDLs (Tp) can be adjusted setting the PDL delay using either on-board dip switches or through register.
When a coincidence occurs (leading edge of COINC signal) the STARTDELAY signal becomes active (high). STARTDELAY triggers a monostable in order to generate a pulse with a duration large enough to ensure maximum linearity performance of the. This value should be more than 320 ns PDL (see 3D3428 component datasheet). The selected value in the reference design is 360 ns.
The PDL_PULSEOUT internal signal is generated as the logic OR of PDL_IN and PDL_OUT, so generating a pulse whose width is proportional to the PDL actual delay. The PDL_PULSEOUT signal falling edge is used to reset the flip-flop state.

The pulse width (Tp) is:
Tp=Tpd+Tpf
Where Tpd is the delay of the selected PDL. (programmable via VME or by on-board dip-switches, whichever mode is enabled).
Tpf is the delay introduced by the FPGA pad and internal logic.
The maximum pulse width is limited by the PDL maximum delay, in this case.

5.5.6. Delay Unit using DLOs

The following diagram shows the implementation of the DELAY_UNIT using two oscillators based on delay lines (DLO) present on the board.



Fig. 5.6: Delay Unit with DLOs



Fig. 5.7: DLOs Delay line timing

When a coincidence occurs (leading edge of COINC signal) the STARTDELAY signal becomes active (high).
STARTDELAY enables the oscillator on external delay line (DLOx) selected via MODE register. At the same time the DELAY_COUNTER is enabled. The PULSE signal leading edge increases the counter until the value set via GATEWIDTH register is reached. The PULSE signal corresponds, in this reference, with the selected PDL output. On the first PULSE leading edge after the coincidence, PULSE_OUT is activated high and is kept high until a time = GATEWIDTH times the period of the selected DLO. The period in this case is constant.
The maximum pulse width is limited by the GATEWIDTH counter: in the case of this reference design the GATEWIDTH register is 16 bit wide, so a maximum width of 65536*Td (Td is the intrinsic delay of the selected DLO).

5.6. Quartus II Web Edition Project

N.B.: the User Demo described in this section is suitable for boards running FPGA VME Firmware Rel. 1.0 and newer

In order to upgrade to FPGA Firmware Rel. 1.0 applications for the FPGA User developed originally on V1495 boards running older firmware releases (for example FPGA VME Firmware Rel. 0.3 and V1495 USER DEMO QuartusII project Rel. 1.1):

- Download the V1495 VME FPGA Firmware Rel. 1.0
- Upgrade FPGA "Bridge" firmware to Rel. 1.0 via VME, through the CVUpgrade tool (see § 5.7)

In order to generate a firmware for the USER FPGA through Altera Quartus II software, compatible with V1495 VME FPGA Firmware Rel. 1.0:

- Download the V1495 USER DEMO QuartusII project Rel. 2.0 and follow the steps described in this section
- At this point applications developed under FPGA Firmware Rel. 0.3 (and older) V1495 USER DEMO QuartusII project Rel. 1.1 (and older) must be updated by incrementing all internal registers address by 0x1000; for instance 0x00FC becomes 0x10FC.

The FPGA "User" is programmable and customizable; the module is delivered configured with the Demo application described by sections § 5.1 through § 5.4.1

The freely available Altera Quartus II (it can be downloaded from the Altera Web site) software must be used in order to generate a user firmware for the USER FPGA. It includes the source of VHDL reference design, which can be modified according to the description provided with the manual, in order to modify the card functionalities.
The tool provides a complete pinout of the FPGA; it is also enabled to generate the file type of programming (RBF format) used for the flash programming.

This software tool requires the Quartus II Web Edition rel. 8.0 (and newer) and can be freely downloaded the download section of the webpage

http://www.caen.it/nuclear/product.php?mod=V1495

Quartus II manual is available at www.altera.com/ website

The following instructions require the User knowledge of the typical project flow for generating the firmware for an ALTERA FPGA.

Once the Quartus II Web Edition is installed on the PC host, in order to open the new project launch the program, then select in the upper toolbar the path
File>Open Project>FIT…



Fig. 5.8: Quartus II project browser

browse the file project v1495usr_demo.qpf

Once the project is open, the Project Navigator shows the following information:

There are 5 VHDL files and a Verilog netlist:

The reference design is included in the coin_reference.vhd file.
The other files provide support to the project and shall not be midified by the developer.

HAL (Hardware Abstraction Layer) is implemented on the netlist Verilog v1495usr_hal.vqm.



Fig. 5.9: Quartus II netlist

The first time the project is launched the hierarchy includes only the name of the head of the project (v1495usr_demo). At the end of the project flow the whole hierarchical structure of the project is shown.



Fig. 5.10: Quartus II hierarchical structure

In order to generate a new programmation file it is necessary to launch the compiler, by clicking on the purple “play” button on the tool bar (see arrow).



Fig. 5.11: Quartus II compiler launching

Quartus at this point launches in sequence the steps of the flow chart (synthesis, fitting, place&route), then shows the correct compiling and the following screen:



Fig. 5.12: Quartus II compiling summary

At this point an updated RBF file is generated in the project directory. This file can be used for updating the firmware.

5.7. Firmware upgrade

It is possible to upgrade the FPGA “Bridge” and the FPGA “User” firmware (see § 1.1) via VME, by writing the Flash: for this purpose, download the software package and the CVUpgrade tool, both available at:
http://www.caen.it/nuclear/product.php?mod=V1495
The instructions are explained by the README text file included in the CVUpgrade folder.